

**Report Item No: 1**

<b>APPLICATION No:</b>	EPF/0660/15
<b>SITE ADDRESS:</b>	Ongar Leisure Centre Fyfield Road Ongar Essex CM5 0GA
<b>PARISH:</b>	Ongar
<b>WARD:</b>	Shelley
<b>DESCRIPTION OF PROPOSAL:</b>	Application for a limited period (2 years) for modular units and associated facilities for school use (Class D1).
<b>DECISION:</b>	Grant Permission - Time Limited Use (With Conditions)

**Click on the link below to view related plans and documents for this case:**

[http://planpub.eppingforestdc.gov.uk/NIM\\_websearch/ExternalEntryPoint.aspx?SEARCH\\_TYPE=1&DOC\\_CLASS\\_CODE=PL&FOLDER1\\_REF=574533](http://planpub.eppingforestdc.gov.uk/NIM_websearch/ExternalEntryPoint.aspx?SEARCH_TYPE=1&DOC_CLASS_CODE=PL&FOLDER1_REF=574533)

The Officer brought the attention of Members to a late representation from Essex County Council Education and Lifelong Learning. The Officer also pointed out amendments to conditions 1 and 10 to allow more time for the removal of the facility until 1<sup>st</sup> September 2015.

**CONDITIONS**

- 1 The use shall cease and the development hereby permitted shall be removed from the site together with any associated materials and the land restored on or before 1 September 2017 leaving afterwards only the hard surfaced area and the perimeter fencing.
- 2 The development hereby permitted will be completed strictly in accordance with the approved drawings nos: 100 P3, 101 P3, 103 P2, 110 P2, 111 P2, 120 P3, SK-002.
- 3 Within 3 months of the commencement of the development, details of foul and surface water drainage disposal shall have been submitted to and approved in writing by the Local Planning Authority. The development shall be implemented in accordance with such agreed details.
- 4 The premises shall be used solely for education purposes and for no other purpose (including any other purpose in Class D1 of the Schedule to the Town & Country Planning (Use Classes) Order 1987 (as amended), or in any provision equivalent to that Class in any Statutory Instrument revoking or re-enacting that Order.
- 5 Notwithstanding the provisions of the Town and Country Planning (General Permitted Development) Order 2015 as amended (or any other Order revoking, further amending or re-enacting that Order) no development generally permitted by virtue of Class M of Part 7 of Schedule 2 to the Order shall be undertaken without the prior written permission of the Local Planning Authority.

- 6 All construction/demolition works and ancillary operations, including vehicle movement on site which are audible at the boundary of noise sensitive premises, shall only take place between the hours of 07.30 to 18.30 Monday to Friday and 08.00 to 13.00 hours on Saturday, and at no time during Sundays and Public/Bank Holidays unless otherwise agreed in writing by the Local Planning Authority.
- 7 The development shall only be undertaken in accordance with Mace Construction Management Plan (5th May 2015) and Mace Site Plan Construction Access, drawing number 103 P2 dated 11th March 2015 unless the Local Planning Authority gives its written consent to any variation. The Management Plan shall be adhered to throughout the construction period.
- 8 All ground works, deliveries and/or demolition shall be in accordance with the submitted Construction Management Plan (CMP) by Mace Ltd. The CMP shall be adhered to throughout the construction period.
- 9 Notwithstanding the draft Travel Plan submitted with this application, prior to first occupation of the development a school travel plan shall be submitted to and approved in writing by the Local Planning Authority.
- 10 The new access gates and barrier fencing shown between Ongar Leisure Centre and Existing Car Park on drawing no. 110 P2 and shall be erected prior to first occupation of the approved building and retained for the full duration of the planning permission after which it shall be removed on or before 1 September 2017 unless otherwise agreed in writing by the Local Planning Authority.
- 11 At no time shall there be ball-games in the play area as shown on drawing no. 110 P2.
- 12 The proposed use of this site has been identified as being particularly vulnerable if land contamination is present, despite no specific former potentially contaminating uses having been identified for this site.

Should any discoloured or odorous soils be encountered during development works or should any hazardous materials or significant quantities of non-soil forming materials be found, then all development works should be stopped, the Local Planning Authority contacted and a scheme to investigate the risks and / or the adoption of any required remedial measures be submitted to, agreed and approved in writing by the Local Planning Authority prior to the recommencement of development works.

Should this occur, following the completion of development works and prior to the first occupation of the site, sufficient information must be submitted to demonstrate that any required remedial measures were satisfactorily implemented or confirmation provided that no unexpected contamination was encountered.

**Report Item No: 2**

<b>APPLICATION No:</b>	EPF/2880/14
<b>SITE ADDRESS:</b>	Blakes Golf Club Epping Road North Weald Epping Essex CM16 6RZ
<b>PARISH:</b>	North Weald Bassett
<b>WARD:</b>	North Weald Bassett
<b>DESCRIPTION OF PROPOSAL:</b>	Application for the importation of topsoil and compost to improve the land quality of the existing driving range and for the use of the land as a driving range and for the purposes of foot golf.
<b>DECISION:</b>	Grant Permission (With Conditions)

**Click on the link below to view related plans and documents for this case:**

[http://planpub.eppingforestdc.gov.uk/NIM\\_websearch/ExternalEntryPoint.aspx?SEARCH\\_TYPE=1&DOC\\_CLASS\\_CODE=PL&FOLDER1\\_REF=572011](http://planpub.eppingforestdc.gov.uk/NIM_websearch/ExternalEntryPoint.aspx?SEARCH_TYPE=1&DOC_CLASS_CODE=PL&FOLDER1_REF=572011)

Members requested that the 3 Ward Councillors and North Weald Parish Councillors be notified of the 6 week period within which the works on site will take place and the 20 days within that period when lorry movement will take place.

**CONDITIONS**

- 1 The development hereby permitted must be begun not later than the expiration of three years beginning with the date of this notice.
- 2 The development hereby permitted will be completed strictly in accordance with the approved drawings nos: WEAL.607B, 0621 03, 0621 02
- 3 Not more than a total of 591 lorry loads of material shall be brought into the site in connection with the development hereby approved, of which 213 loads shall be compost from the Ashlyns Farm Site opposite the application site as specified in the supporting information.
- 4 All lorries to and from the site shall be routed from the A414 only and shall not travel through North Weald or Ongar. All lorries exiting the site shall be required to turn left onto the A414.
- 5 All works on site shall be completed within a 6 week period. The proposed lorry movements shall take place on a maximum of 20 days (cumulatively) within that six week period. Prior to the commencement of development a timetable of works specifying the six week period in which all works will be completed and the 20 dates within that period on which lorry movements will take place, shall be submitted to and agreed in writing by the Local Planning Authority. Works shall thereafter be carried out in accordance with the agreed timetable.

- 6 No external lighting shall be installed in connection with the development hereby approved unless agreed in writing by the Local Planning Authority prior to its installation. Full details of any external lighting shall be submitted to the Local Planning Authority for approval and shall thereafter be carried out in accordance with the approved details.
- 7 The amount of material brought in for the purposes of this development shall not exceed 8000 cubic metres in volume made up of 5800m<sup>3</sup> of topsoil and compost and 2200m<sup>3</sup> of engineering clay, all of which shall be used for the development hereby approved.
- 8 No development shall take place until a Phase 1 Land Contamination investigation has been carried out. A protocol for the investigation shall be submitted to and approved in writing by the Local Planning Authority before commencement of the Phase 1 investigation. The completed Phase 1 report shall be submitted to and approved in writing by the Local Planning Authority prior to the commencement of any necessary Phase 2 investigation. The report shall assess potential risks to present and proposed humans, property including buildings, crops, livestock, pets, woodland and service lines and pipes, adjoining land, groundwaters and surface waters, ecological systems, archaeological sites and ancient monuments and the investigation must be conducted in accordance with DEFRA and the Environment Agency's "Model Procedures for the Management of Land Contamination, CLR 11", or any subsequent version or additional regulatory guidance.  
[Note: This condition must be formally discharged by the Local Planning Authority before the submission of details pursuant to the Phase 2 site investigation condition that follows]
- 9 Should the Phase 1 Land Contamination preliminary risk assessment carried out under the above condition identify the presence of potentially unacceptable risks, no development shall take place until a Phase 2 site investigation has been carried out. A protocol for the investigation shall be submitted to and approved by the Local Planning Authority before commencement of the Phase 2 investigation. The completed Phase 2 investigation report, together with any necessary outline remediation options, shall be submitted to and approved by the Local Planning Authority prior to any redevelopment or remediation works being carried out. The report shall assess potential risks to present and proposed humans, property including buildings, crops, livestock, pets, woodland and service lines and pipes, adjoining land, groundwaters and surface waters, ecological systems, archaeological sites and ancient monuments and the investigation must be conducted in accordance with DEFRA and the Environment Agency's "Model Procedures for the Management of Land Contamination, CLR 11", or any subsequent version or additional regulatory guidance.  
[Note: This condition must be formally discharged by the Local Planning Authority before the submission of details pursuant to the remediation scheme condition that follows]
- 10 Should Land Contamination Remediation Works be identified as necessary under the above condition, no development shall take place until a detailed remediation scheme to bring the site to a condition suitable for the intended use has been submitted to and approved by the Local Planning Authority. The development shall be carried out in accordance with the approved remediation scheme unless otherwise agreed in writing by the Local Planning Authority. The remediation scheme must include all works to be undertaken, proposed remediation objectives and remediation criteria, timetable of works and site management procedures and any necessary long term maintenance and monitoring programme. The scheme

must ensure that the site will not qualify as contaminated land under Part 2A of the Environmental Protection Act 1990 or any subsequent version, in relation to the intended use of the land after remediation.

[Note: This condition must be formally discharged by the Local Planning Authority before the submission of details pursuant to the verification report condition that follows]

- 11 Following completion of measures identified in the approved remediation scheme and prior to the first use or occupation of the development, a verification report that demonstrates the effectiveness of the remediation carried out must be produced together with any necessary monitoring and maintenance programme and copies of any waste transfer notes relating to exported and imported soils shall be submitted to the Local Planning Authority for approval. The approved monitoring and maintenance programme shall be implemented.
- 12 In the event that any evidence of potential contamination is found at any time when carrying out the approved development that was not previously identified in the approved Phase 2 report, it must be reported in writing immediately to the Local Planning Authority. An investigation and risk assessment must be undertaken in accordance with a methodology previously approved by the Local Planning Authority. Following completion of measures identified in the approved remediation scheme, a verification report must be prepared, which is subject to the approval in writing of the Local Planning Authority in accordance with the immediately above condition.

**Report Item No: 3**

<b>APPLICATION No:</b>	EPF/0459/15
<b>SITE ADDRESS:</b>	31 Piercing Hill Theydon Bois Epping Essex CM16 7JW
<b>PARISH:</b>	Theydon Bois
<b>WARD:</b>	Theydon Bois
<b>DESCRIPTION OF PROPOSAL:</b>	Raising of height of roof and provision of three dormer windows at front and three to the rear, erection of part one, part two and part three storey rear extensions and conversion of garage into a gym. (Revision of planning permission EPF/2150/11).
<b>DECISION:</b>	Deferred for Site Visit

**Click on the link below to view related plans and documents for this case:**

[http://planpub.eppingforestdc.gov.uk/NIM\\_websearch/ExternalEntryPoint.aspx?SEARCH\\_TYPE=1&DOC\\_CLASS\\_CODE=PL&FOLDER1\\_REF=574038](http://planpub.eppingforestdc.gov.uk/NIM_websearch/ExternalEntryPoint.aspx?SEARCH_TYPE=1&DOC_CLASS_CODE=PL&FOLDER1_REF=574038)

Members deferred this item in order that a site visit could be undertaken.

**CONDITIONS**

- 1 The development hereby permitted must be begun not later than the expiration of three years beginning with the date of this notice.
- 2 Materials to be used for the external finishes of the proposed development shall match those of the existing building, unless otherwise agreed in writing by the Local Planning Authority.
- 3 No development, including works of demolition or site clearance, shall take place until a Tree Protection Plan Arboricultural Method Statement and site monitoring schedule in accordance with BS:5837:2012 (Trees in relation to design, demolition and construction - recommendations) has been submitted to the Local Planning Authority and approved in writing. The development shall be carried out only in accordance with the approved documents unless the Local Planning Authority gives its written consent to any variation.
- 4 Prior to first occupation of the development hereby approved, the proposed window openings in the first floor flank elevation facing south towards the neighbouring Coopers Court, shall be entirely fitted with obscured glass and have fixed frames to a height of 1.7 metres above the floor of the room in which the window is installed and shall be permanently retained in that condition.

**Report Item No: 4**

<b>APPLICATION No:</b>	EPF/0535/15
<b>SITE ADDRESS:</b>	Copper Beech Harlow Common North Weald Essex CM17 9ND
<b>PARISH:</b>	North Weald Bassett
<b>WARD:</b>	Hastingwood, Matching and Sheering Village
<b>DESCRIPTION OF PROPOSAL:</b>	Proposed replacement dwelling and garage block in lieu of existing dwelling and outbuildings. Re-application of EPF/2903/14.
<b>DECISION:</b>	Application withdrawn by Applicant

**Click on the link below to view related plans and documents for this case:**

[http://planpub.eppingforestdc.gov.uk/NIM\\_websearch/ExternalEntryPoint.aspx?SEARCH\\_TYPE=1&DOC\\_CLASS\\_CODE=PL&FOLDER1\\_REF=574219](http://planpub.eppingforestdc.gov.uk/NIM_websearch/ExternalEntryPoint.aspx?SEARCH_TYPE=1&DOC_CLASS_CODE=PL&FOLDER1_REF=574219)

**Report Item No: 5**

<b>APPLICATION No:</b>	EPF/0663/15
<b>SITE ADDRESS:</b>	Epping Magistrates Court Hemnall Street Epping Essex CM16 4LU
<b>PARISH:</b>	Epping
<b>WARD:</b>	Epping Hemnall
<b>DESCRIPTION OF PROPOSAL:</b>	Demolition of Epping Magistrates Court and redevelopment to provide 8 apartments with associated access, car parking and hard landscaping.
<b>DECISION:</b>	Agreed to Grant Permission (Subject to Legal Agreement)

**Click on the link below to view related plans and documents for this case:**

[http://planpub.eppingforestdc.gov.uk/NIM\\_websearch/ExternalEntryPoint.aspx?SEARCH\\_TYPE=1&DOC\\_CLASS\\_CODE=PL&FOLDER1\\_REF=574536](http://planpub.eppingforestdc.gov.uk/NIM_websearch/ExternalEntryPoint.aspx?SEARCH_TYPE=1&DOC_CLASS_CODE=PL&FOLDER1_REF=574536)

**CONDITIONS**

- 1 The development hereby permitted must be begun not later than the expiration of three years beginning with the date of this notice.
- 2 The development hereby permitted will be completed strictly in accordance with the approved drawings No's: 768-PI-01, 02, 03, location plan.
- 3 No development shall have taken place until samples of the types and colours of the external finishes have been submitted to and approved by the Local Planning Authority in writing prior to the commencement of the development. The development shall be implemented in accordance with such approved details. For the purposes of this condition, the samples shall only be made available for inspection by the Local Planning Authority at the planning application site itself.
- 4 The proposed development shall be carried out in accordance with the flood risk assessment (Richard Jackson Engineering Consultants -Proposed Redevelopment- Epping Magistrates Court, Project 45660, March 2015) and drainage plan (45660/P/SK01) submitted with the application unless otherwise agreed in writing with the Local Planning Authority
- 5 Prior to the commencement of any works dusk and dawn surveys for bats should be undertaken in accordance with guidelines from Natural England (or other relevant body) and submitted to the Council for approval. Should the surveys reveal the presence of bats, or their breeding sites or resting places then an appropriate and proportionate detailed mitigation and compensation strategy must be written in accordance with any guidelines available from Natural England (or other relevant body) and submitted to for approval.

Should a Natural England European Protected Species licence (EPS) be required then this should also be submitted to the Council. The licence will be granted if the

activity conforms with the Habitats Regulations Regulation 53 Three Stage Test and Local Authority planning consent has been granted.

All works shall then proceed in accordance with the approved strategy with any amendments agreed in writing.

- 6 No development or preliminary groundworks of any kind shall take place until the applicant has secured the implementation of a programme of archaeological work, including a photographic recording of the building, in accordance with a written scheme of investigation which has been submitted by the applicant and approved by the local planning authority.
- 7 No development shall take place until wheel washing or other cleaning facilities for vehicles leaving the site during construction works have been installed in accordance with details which shall be submitted to and agreed in writing by the Local Planning Authority. The approved installed cleaning facilities shall be used to clean vehicles immediately before leaving the site.
- 8 No development shall take place until details of levels have been submitted to and approved by the Local Planning Authority showing cross-sections and elevations of the levels of the site prior to development and the proposed levels of all ground floor slabs of buildings, roadways and accessways and landscaped areas. The development shall be carried out in accordance with those approved details.
- 9 All construction/demolition works and ancillary operations, including vehicle movement on site which are audible at the boundary of noise sensitive premises, shall only take place between the hours of 07.30 to 18.30 Monday to Friday and 08.00 to 13.00 hours on Saturday, and at no time during Sundays and Public/Bank Holidays unless otherwise agreed in writing by the Local Planning Authority.
- 10 Prior to the first occupation of the development the vehicle parking and turning areas as indicated on the approved plans shall be provided, hard surfaced, sealed and marked out. The parking and turning areas shall be retained in perpetuity for their intended purpose.
- 11 Prior to first occupation of the development, the Developer shall be responsible for the provision, per dwelling, and implementation of a Residential Travel Information Pack for sustainable transport, approved by Essex County Council, to include six one day travel vouchers for use with the relevant local public transport operator.

**Subject to the completion of an agreement under S.106 of the Town and Country Planning Act 1990 agreeing a timeframe for the redevelopment of the site following demolition.**

**Report Item No: 6**

<b>APPLICATION No:</b>	EPF/0670/15
<b>SITE ADDRESS:</b>	The Laurels New Road Lambourne End Essex RM4 1DY
<b>PARISH:</b>	Lambourne
<b>WARD:</b>	Lambourne
<b>DESCRIPTION OF PROPOSAL:</b>	Demolition of single storey annexe to the rear and erection of a part one and part two storey dwelling on land to the rear with a self contained annexe on the first floor.
<b>DECISION:</b>	Grant Permission (with Conditions)

**Click on the link below to view related plans and documents for this case:**

[http://planpub.eppingforestdc.gov.uk/NIM\\_websearch/ExternalEntryPoint.aspx?SEARCH\\_TYPE=1&DOC\\_CLASS\\_CODE=PL&FOLDER1\\_REF=574593](http://planpub.eppingforestdc.gov.uk/NIM_websearch/ExternalEntryPoint.aspx?SEARCH_TYPE=1&DOC_CLASS_CODE=PL&FOLDER1_REF=574593)

**CONDITIONS**

- 1 The development hereby permitted must be begun not later than the expiration of three years beginning with the date of this notice.
- 2 No construction works above ground level shall take place until documentary and photographic details of the types and colours of the external finishes have been submitted to and approved by the Local Planning Authority, in writing. The development shall be implemented in accordance with such approved details.
- 3 All buildings, structures and land containers shown to be removed on the approved plan, shall be fully removed from the site prior to first occupation of the dwelling hereby approved.
- 4 Notwithstanding the provisions of the Town and Country Planning (General Permitted Development) (England) Order 2015 as amended (or any other Order revoking, further amending or re-enacting that Order) no development generally permitted by virtue of Class A, B and E of Part 1 of Schedule 2 to the Order shall be undertaken without the prior written permission of the Local Planning Authority.
- 5 The first occupants of the dwelling hereby approved shall be the applicants, Mr and Mrs. K. Green and their son, Steven.
- 6 All construction/demolition works and ancillary operations, including vehicle movement on site which are audible at the boundary of noise sensitive premises, shall only take place between the hours of 07.30 to 18.30 Monday to Friday and 08.00 to 13.00 hours on Saturday, and at no time during Sundays and Public/Bank Holidays unless otherwise agreed in writing by the Local Planning Authority.

- 7 No development shall take place until details of foul and surface water disposal have been submitted to and approved in writing by the Local Planning Authority. The development shall be implemented in accordance with such agreed details.
- 8 The conifer and trees on the boundaries of the site shall be retained unless otherwise agreed in writing by the Local Planning Authority.
- 9 The development hereby permitted will be completed strictly in accordance with the approved drawings nos: 1255/11A, 1255.21, 1255.31, 1255.41, 1255/51, 1255.61

**Report Item No: 7**

<b>APPLICATION No:</b>	EPF/0680/15
<b>SITE ADDRESS:</b>	94-96 High Road North Weald Bassett Essex CM16 6BY
<b>PARISH:</b>	North Weald Bassett
<b>WARD:</b>	North Weald Bassett
<b>DESCRIPTION OF PROPOSAL:</b>	Proposed 1 no. 2 bed flat and 1 no 1 bed flat in the existing roof of the property with front, side and rear dormer windows. Two storey front extension to gain access to flats in roof (Revision to EPF/2827/14)
<b>DECISION:</b>	Deferred

**Click on the link below to view related plans and documents for this case:**

[http://planpub.eppingforestdc.gov.uk/NIM\\_websearch/ExternalEntryPoint.aspx?SEARCH\\_TYPE=1&DOC\\_CLASS\\_CODE=PL&FOLDER1\\_REF=574616](http://planpub.eppingforestdc.gov.uk/NIM_websearch/ExternalEntryPoint.aspx?SEARCH_TYPE=1&DOC_CLASS_CODE=PL&FOLDER1_REF=574616)

Members deferred this item in order that a site visit could be undertaken and more information supplied.

**CONDITIONS**

- 1 The development hereby permitted must be begun not later than the expiration of three years beginning with the date of this notice.
- 2 Materials to be used for the external finishes of the proposed development shall match those of the existing building, unless otherwise agreed in writing by the Local Planning Authority.
- 3 The development hereby permitted will be completed strictly in accordance with the approved drawings nos: ONWEF/14/1-3, 04a (received amended 4/6/15), 5b (received amended 4/6/15), 6a, 7a, 8b (received amended 4/6/15), 9a (received amended 4/6/15), 11, 15, 16, location plan.
- 4 The proposed window opening in the flank elevation serving the dormer window shall be fitted with obscured glass and have fixed frames to a height of 1.7 metres above the floor of the room in which the window is installed and shall be permanently retained in that condition.
- 5 The parking area shown on the submitted plans shall be permanently retained for this purpose and remain free from obstruction which prevents the parking of vehicles.

**Report Item No: 8**

<b>APPLICATION No:</b>	EPF/0692/15
<b>SITE ADDRESS:</b>	Land to the rear of Triptons Oak Hill Road Stapleford Abbots Essex RM4 1JJ
<b>PARISH:</b>	Stapleford Abbots
<b>WARD:</b>	Passingford
<b>DESCRIPTION OF PROPOSAL:</b>	Demolition of existing buildings, erection of two bungalows, formation of four parking spaces, erection of garden fencing.
<b>DECISION:</b>	Deferred

**Click on the link below to view related plans and documents for this case:**

[http://planpub.eppingforestdc.gov.uk/NIM\\_websearch/ExternalEntryPoint.aspx?SEARCH\\_TYPE=1&DOC\\_CLASS\\_CODE=PL&FOLDER1\\_REF=574654](http://planpub.eppingforestdc.gov.uk/NIM_websearch/ExternalEntryPoint.aspx?SEARCH_TYPE=1&DOC_CLASS_CODE=PL&FOLDER1_REF=574654)

Due to time constraints this item was not heard. It will be considered at the next meeting on the 15th July.

**CONDITIONS**

- 1 The development hereby permitted must be begun not later than the expiration of three years beginning with the date of this notice.
- 2 The public's rights and ease of passage over public footpath no.26 Stapleford Abbots shall be maintained free and unobstructed at all times.
- 3 A flood risk assessment and management and maintenance plan shall be submitted to and approved by the Local Planning Authority prior to the commencement of the development. The assessment shall demonstrate that adjacent properties shall not be subject to increased flood risk and, dependant upon the capacity of the receiving drainage, shall include calculations of any increased storm run-off and the necessary on-site detention. The approved measures shall be carried out prior to the substantial completion of the development hereby approved and shall be adequately maintained in accordance with the approved management and maintenance plan.
- 4 No development shall take place until details of foul and surface water disposal have been submitted to and approved in writing by the Local Planning Authority. The development shall be implemented in accordance with such agreed details.
- 5 All construction/demolition works and ancillary operations, including vehicle movement on site which are audible at the boundary of noise sensitive premises, shall only take place between the hours of 07.30 to 18.30 Monday to Friday and 08.00 to 13.00 hours on Saturday, and at no time during Sundays and Public/Bank Holidays unless otherwise agreed in writing by the Local Planning Authority.

- 6 No development shall take place until a Phase 1 Land Contamination investigation has been carried out. A protocol for the investigation shall be submitted to and approved in writing by the Local Planning Authority before commencement of the Phase 1 investigation. The completed Phase 1 report shall be submitted to and approved in writing by the Local Planning Authority prior to the commencement of any necessary Phase 2 investigation. The report shall assess potential risks to present and proposed humans, property including buildings, crops, livestock, pets, woodland and service lines and pipes, adjoining land, groundwaters and surface waters, ecological systems, archaeological sites and ancient monuments and the investigation must be conducted in accordance with DEFRA and the Environment Agency's "Model Procedures for the Management of Land Contamination, CLR 11", or any subsequent version or additional regulatory guidance.  
[Note: This condition must be formally discharged by the Local Planning Authority before the submission of details pursuant to the Phase 2 site investigation condition that follows]
- 7 Should the Phase 1 Land Contamination preliminary risk assessment carried out under the above condition identify the presence of potentially unacceptable risks, no development shall take place until a Phase 2 site investigation has been carried out. A protocol for the investigation shall be submitted to and approved by the Local Planning Authority before commencement of the Phase 2 investigation. The completed Phase 2 investigation report, together with any necessary outline remediation options, shall be submitted to and approved by the Local Planning Authority prior to any redevelopment or remediation works being carried out. The report shall assess potential risks to present and proposed humans, property including buildings, crops, livestock, pets, woodland and service lines and pipes, adjoining land, groundwaters and surface waters, ecological systems, archaeological sites and ancient monuments and the investigation must be conducted in accordance with DEFRA and the Environment Agency's "Model Procedures for the Management of Land Contamination, CLR 11", or any subsequent version or additional regulatory guidance.  
[Note: This condition must be formally discharged by the Local Planning Authority before the submission of details pursuant to the remediation scheme condition that follows]
- 8 Should Land Contamination Remediation Works be identified as necessary under the above condition, no development shall take place until a detailed remediation scheme to bring the site to a condition suitable for the intended use has been submitted to and approved by the Local Planning Authority. The development shall be carried out in accordance with the approved remediation scheme unless otherwise agreed in writing by the Local Planning Authority. The remediation scheme must include all works to be undertaken, proposed remediation objectives and remediation criteria, timetable of works and site management procedures and any necessary long term maintenance and monitoring programme. The scheme must ensure that the site will not qualify as contaminated land under Part 2A of the Environmental Protection Act 1990 or any subsequent version, in relation to the intended use of the land after remediation.  
[Note: This condition must be formally discharged by the Local Planning Authority before the submission of details pursuant to the verification report condition that follows]
- 9 Following completion of measures identified in the approved remediation scheme and prior to the first use or occupation of the development, a verification report that demonstrates the effectiveness of the remediation carried out must be produced together with any necessary monitoring and maintenance programme and copies of

any waste transfer notes relating to exported and imported soils shall be submitted to the Local Planning Authority for approval. The approved monitoring and maintenance programme shall be implemented.

- 10 In the event that any evidence of potential contamination is found at any time when carrying out the approved development that was not previously identified in the approved Phase 2 report, it must be reported in writing immediately to the Local Planning Authority. An investigation and risk assessment must be undertaken in accordance with a methodology previously approved by the Local Planning Authority. Following completion of measures identified in the approved remediation scheme, a verification report must be prepared, which is subject to the approval in writing of the Local Planning Authority in accordance with the immediately above condition.
- 11 No construction works above ground level shall take place until documentary and photographic details of the types and colours of the external finishes have been submitted to and approved by the Local Planning Authority, in writing. The development shall be implemented in accordance with such approved details.
- 12 Notwithstanding the provisions of the Town and Country Planning (General Permitted Development) Order 2015 as amended (or any other Order revoking, further amending or re-enacting that Order) no development generally permitted by virtue of Class A of Part 1 of Schedule 2 to the Order shall be undertaken without the prior written permission of the Local Planning Authority.
- 13 No development shall take place until wheel washing or other cleaning facilities for vehicles leaving the site during construction works have been installed in accordance with details which shall be submitted to and agreed in writing by the Local Planning Authority. The approved installed cleaning facilities shall be used to clean vehicles immediately before leaving the site.
- 14 The development hereby permitted will be completed strictly in accordance with the approved drawings nos: 1287.1A, .2A, 3 and 4

**Report Item No: 9**

<b>APPLICATION No:</b>	EPF/0735/15
<b>SITE ADDRESS:</b>	Home Farm Barns Stewards Green Road Fiddlers Hamlet Epping Essex CM16 7PG
<b>PARISH:</b>	Epping
<b>WARD:</b>	Epping Hemnall
<b>DESCRIPTION OF PROPOSAL:</b>	Demolition of existing buildings and structures, and erection of 2 new dwellings
<b>DECISION:</b>	Grant Permission (With Conditions)

**Click on the link below to view related plans and documents for this case:**

[http://planpub.eppingforestdc.gov.uk/NIM\\_websearch/ExternalEntryPoint.aspx?SEARCH\\_TYPE=1&DOC\\_CLASS\\_CODE=PL&FOLDER1\\_REF=574734](http://planpub.eppingforestdc.gov.uk/NIM_websearch/ExternalEntryPoint.aspx?SEARCH_TYPE=1&DOC_CLASS_CODE=PL&FOLDER1_REF=574734)

**CONDITIONS**

- 1 The development hereby permitted must be begun not later than the expiration of three years beginning with the date of this notice.
- 2 The development hereby permitted will be completed strictly in accordance with the approved drawings nos: Job No. 1304 Drawing numbers : 1340\_001 Rev PP3, 1304\_002 PP4, 1304\_003 PP3, 1304\_004 PP2, 1304\_005 PP2, 1304\_006 PP1, 1304\_008 PP4, 009 PP3, 010 PP3, 1304\_013 PP2, 014 PP2, 015 PP2.
- 3 No construction works above ground level shall take place until documentary and photographic details of the types and colours of the external finishes have been submitted to and approved by the Local Planning Authority, in writing. The development shall be implemented in accordance with such approved details.
- 4 The development shall be carried out in accordance with the flood risk assessment (ref:CCE/N531/FRA-01 December 2013) and drainage strategy submitted with the application unless otherwise agreed in writing by the Local Planning Authority.
- 5 All construction/demolition works and ancillary operations, including vehicle movement on site which are audible at the boundary of noise sensitive premises, shall only take place between the hours of 07.30 to 18.30 Monday to Friday and 08.00 to 13.00 hours on Saturday, and at no time during Sundays and Public/Bank Holidays unless otherwise agreed in writing by the Local Planning Authority.
- 6 No development shall take place until a Phase 1 Land Contamination investigation has been carried out. A protocol for the investigation shall be submitted to and approved in writing by the Local Planning Authority before commencement of the Phase 1 investigation. The completed Phase 1 report shall be submitted to and approved in writing by the Local Planning Authority prior to the commencement of any necessary Phase 2 investigation. The report shall assess potential risks to

present and proposed humans, property including buildings, crops, livestock, pets, woodland and service lines and pipes, adjoining land, groundwaters and surface waters, ecological systems, archaeological sites and ancient monuments and the investigation must be conducted in accordance with DEFRA and the Environment Agency's "Model Procedures for the Management of Land Contamination, CLR 11", or any subsequent version or additional regulatory guidance.

[Note: This condition must be formally discharged by the Local Planning Authority before the submission of details pursuant to the Phase 2 site investigation condition that follows]

- 7 Should the Phase 1 Land Contamination preliminary risk assessment carried out under the above condition identify the presence of potentially unacceptable risks, no development shall take place until a Phase 2 site investigation has been carried out. A protocol for the investigation shall be submitted to and approved by the Local Planning Authority before commencement of the Phase 2 investigation. The completed Phase 2 investigation report, together with any necessary outline remediation options, shall be submitted to and approved by the Local Planning Authority prior to any redevelopment or remediation works being carried out. The report shall assess potential risks to present and proposed humans, property including buildings, crops, livestock, pets, woodland and service lines and pipes, adjoining land, groundwaters and surface waters, ecological systems, archaeological sites and ancient monuments and the investigation must be conducted in accordance with DEFRA and the Environment Agency's "Model Procedures for the Management of Land Contamination, CLR 11", or any subsequent version or additional regulatory guidance.  
[Note: This condition must be formally discharged by the Local Planning Authority before the submission of details pursuant to the remediation scheme condition that follows]
- 8 Should Land Contamination Remediation Works be identified as necessary under the above condition, no development shall take place until a detailed remediation scheme to bring the site to a condition suitable for the intended use has been submitted to and approved by the Local Planning Authority. The development shall be carried out in accordance with the approved remediation scheme unless otherwise agreed in writing by the Local Planning Authority. The remediation scheme must include all works to be undertaken, proposed remediation objectives and remediation criteria, timetable of works and site management procedures and any necessary long term maintenance and monitoring programme. The scheme must ensure that the site will not qualify as contaminated land under Part 2A of the Environmental Protection Act 1990 or any subsequent version, in relation to the intended use of the land after remediation.  
[Note: This condition must be formally discharged by the Local Planning Authority before the submission of details pursuant to the verification report condition that follows]
- 9 Following completion of measures identified in the approved remediation scheme and prior to the first use or occupation of the development, a verification report that demonstrates the effectiveness of the remediation carried out must be produced together with any necessary monitoring and maintenance programme and copies of any waste transfer notes relating to exported and imported soils shall be submitted to the Local Planning Authority for approval. The approved monitoring and maintenance programme shall be implemented.

- 10 In the event that any evidence of potential contamination is found at any time when carrying out the approved development that was not previously identified in the approved Phase 2 report, it must be reported in writing immediately to the Local Planning Authority. An investigation and risk assessment must be undertaken in accordance with a methodology previously approved by the Local Planning Authority. Following completion of measures identified in the approved remediation scheme, a verification report must be prepared, which is subject to the approval in writing of the Local Planning Authority in accordance with the immediately above condition.
- 11 Prior to first occupation of the development the proposed private drive shall be constructed to a width of 5.5 metres for at least the first 6 metres from the back of carriageway and provided with an appropriate dropped kerb crossing of the highway verge.
- 12 Prior to the first occupation of the development the vehicle parking and turning areas as indicated on the approved plans shall be provided, hard surfaced and sealed. The parking and turning areas shall be retained in perpetuity for their intended purpose.
- 13 No unbound material shall be used in the surface treatment of the vehicular access within 6 metres of the highway boundary.
- 14 There shall be no discharge of surface water onto the Highway.
- 15 No development shall take place until details of foul and surface water disposal have been submitted to and approved in writing by the Local Planning Authority. The development shall be implemented in accordance with such agreed details.
- 16 No development shall take place, including site clearance or other preparatory work, until full details of both hard and soft landscape works (including tree planting) and implementation programme (linked to the development schedule) have been submitted to and approved in writing by the Local Planning Authority. These works shall be carried out as approved. The hard landscaping details shall include, as appropriate, and in addition to details of existing features to be retained: proposed finished levels or contours; means of enclosure; car parking layouts; other minor artefacts and structures, including signs and lighting and functional services above and below ground. The details of soft landscape works shall include plans for planting or establishment by any means and full written specifications and schedules of plants, including species, plant sizes and proposed numbers /densities where appropriate. If within a period of five years from the date of the planting or establishment of any tree, or shrub or plant, that tree, shrub, or plant or any replacement is removed, uprooted or destroyed or dies or becomes seriously damaged or defective another tree or shrub, or plant of the same species and size as that originally planted shall be planted at the same place, unless the Local Planning Authority gives its written consent to any variation.
- 17 No development, including works of demolition or site clearance, shall take place until a Tree Protection Plan Arboricultural Method Statement and site monitoring schedule in accordance with BS:5837:2012 (Trees in relation to design, demolition and construction - recommendations) has been submitted to the Local Planning Authority and approved in writing. The development shall be carried out only in accordance with the approved documents unless the Local Planning Authority gives its written consent to any variation.

- 18 The precautionary clearance methods as identified in Section 5 of the submitted Extended Phase 1 Habitat Report P2175.3.0 shall be undertaken, and prior to the completion of the development details of habitat enhancement shall be submitted to and agreed in writing by the Local planning Authority. The agreed enhancements shall be completed prior to the first occupation of the dwellings hereby approved.
- 19 Notwithstanding the provisions of the Town & Country Planning (General Permitted Development Order) England 2015 (or of any equivalent provision in any Statutory Instrument revoking or re-enacting that Order), the garages hereby approved shall be retained so that they are capable of allowing the parking of cars together with any ancillary storage in connection with the residential use of the site, and shall at no time be converted into a room or used for any other purpose.
- 20 Notwithstanding the provisions of the Town and Country Planning (General Permitted Development) (England) Order 2015 as amended (or any other Order revoking, further amending or re-enacting that Order) no development generally permitted by virtue of Classes A, B and E of Part 1 of Schedule 2 to the Order shall be undertaken without the prior written permission of the Local Planning Authority.
- 21 No gates shall be erected at the entrance to the site.

**Report Item No: 10**

<b>APPLICATION No:</b>	EPF/0744/15
<b>SITE ADDRESS:</b>	90 The Orchards Epping Essex CM16 7AT
<b>PARISH:</b>	Epping
<b>WARD:</b>	Epping Hemnall
<b>DESCRIPTION OF PROPOSAL:</b>	Proposed single storey side/rear extension and garage conversion
<b>DECISION:</b>	Deferred

**Click on the link below to view related plans and documents for this case:**

[http://planpub.eppingforestdc.gov.uk/NIM\\_websearch/ExternalEntryPoint.aspx?SEARCH\\_TYPE=1&DOC\\_CLASS\\_CODE=PL&FOLDER1\\_REF=574773](http://planpub.eppingforestdc.gov.uk/NIM_websearch/ExternalEntryPoint.aspx?SEARCH_TYPE=1&DOC_CLASS_CODE=PL&FOLDER1_REF=574773)

Due to time constraints this item was not heard. It will be considered at the next meeting on the 15th July.

**CONDITIONS**

- 1 The development hereby permitted must be begun not later than the expiration of three years beginning with the date of this notice.
- 2 Materials to be used for the external finishes of the proposed development shall match those of the existing building, unless otherwise agreed in writing by the Local Planning Authority.
- 3 All construction/demolition works and ancillary operations, including vehicle movement on site which are audible at the boundary of noise sensitive premises, shall only take place between the hours of 07.30 to 18.30 Monday to Friday and 08.00 to 13.00 hours on Saturday, and at no time during Sundays and Public/Bank Holidays unless otherwise agreed in writing by the Local Planning Authority.

**Report Item No: 11**

<b>APPLICATION No:</b>	EPF/0753/15
<b>SITE ADDRESS:</b>	22 Coopersale Street Epping Essex CM16 7QJ
<b>PARISH:</b>	Epping
<b>WARD:</b>	Epping Hemnall
<b>DESCRIPTION OF PROPOSAL:</b>	Construction of detached amenity outbuilding
<b>DECISION:</b>	Deferred

**Click on the link below to view related plans and documents for this case:**

[http://planpub.eppingforestdc.gov.uk/NIM.websearch/ExternalEntryPoint.aspx?SEARCH\\_TYPE=1&DOC\\_CLASS\\_CODE=PL&FOLDER1\\_REF=574815](http://planpub.eppingforestdc.gov.uk/NIM.websearch/ExternalEntryPoint.aspx?SEARCH_TYPE=1&DOC_CLASS_CODE=PL&FOLDER1_REF=574815)

Due to time constraints this item was not heard. It will be considered at the next meeting on the 15th July.

**CONDITIONS**

- 1 The development hereby permitted must be begun not later than the expiration of three years beginning with the date of this notice.
- 2 No development shall have taken place until samples of the types and colours of the external finishes have been submitted to and approved by the Local Planning Authority in writing prior to the commencement of the development. The development shall be implemented in accordance with such approved details. For the purposes of this condition, the samples shall only be made available for inspection by the Local Planning Authority at the planning application site itself.
- 3 No development, including works of demolition or site clearance, shall take place until a Tree Protection Plan Arboricultural Method Statement and site monitoring schedule in accordance with BS:5837:2012 (Trees in relation to design, demolition and construction - recommendations) has been submitted to the Local Planning Authority and approved in writing. The development shall be carried out only in accordance with the approved documents unless the Local Planning Authority gives its written consent to any variation.
- 4 No development shall take place, including site clearance or other preparatory work, until full details of both hard and soft landscape works (including tree planting) and implementation programme (linked to the development schedule) have been submitted to an approved in writing by the Local Planning Authority. These works shall be carried out as approved. The hard landscaping details shall include, as appropriate, and in addition to details of existing features to be retained: proposed finished levels or contours; means of enclosure; car parking layouts; other minor artefacts and structures, including signs and lighting and functional services above and below ground. The details of soft landscape works shall include plans for planting or establishment by any means and full written specifications and schedules of plants, including species, plant sizes and proposed numbers /densities where

appropriate. If within a period of five years from the date of the planting or establishment of any tree, or shrub or plant, that tree, shrub, or plant or any replacement is removed, uprooted or destroyed or dies or becomes seriously damaged or defective another tree or shrub, or plant of the same species and size as that originally planted shall be planted at the same place, unless the Local Planning Authority gives its written consent to any variation.

**Report Item No: 12**

<b>APPLICATION No:</b>	EPF/0851/15
<b>SITE ADDRESS:</b>	Pizza Express 208-212 High Street Epping Essex CM16 4AQ
<b>PARISH:</b>	Epping
<b>WARD:</b>	Epping Hemnall
<b>DESCRIPTION OF PROPOSAL:</b>	Advertisement consent for two externally illuminated projecting signs, and halo illuminated individual fascia lettering.
<b>DECISION:</b>	Deferred

**Click on the link below to view related plans and documents for this case:**

[http://planpub.eppingforestdc.gov.uk/NIM\\_websearch/ExternalEntryPoint.aspx?SEARCH\\_TYPE=1&DOC\\_CLASS\\_CODE=PL&FOLDER1\\_REF=575055](http://planpub.eppingforestdc.gov.uk/NIM_websearch/ExternalEntryPoint.aspx?SEARCH_TYPE=1&DOC_CLASS_CODE=PL&FOLDER1_REF=575055)

Due to time constraints this item was not heard. It will be considered at the next meeting on the 15th July.

**CONDITIONS**

- 1 The maximum luminance of the signs granted consent by this Notice shall not exceed 100 candelas per square metre.
- 2 The development hereby permitted will be completed strictly in accordance with the approved drawings nos: 1139/02 E

**Report Item No: 13**

<b>APPLICATION No:</b>	EPF/0871/15
<b>SITE ADDRESS:</b>	22 Bower Hill Epping Essex CM16 7AD
<b>PARISH:</b>	Epping
<b>WARD:</b>	Epping Hemnall
<b>DESCRIPTION OF PROPOSAL:</b>	Creation of parking area to front of property to include a vehicular crossover.
<b>DECISION:</b>	Grant Permission (With Conditions)

**Click on the link below to view related plans and documents for this case:**

[http://planpub.eppingforestdc.gov.uk/NIM.websearch/ExternalEntryPoint.aspx?SEARCH\\_TYPE=1&DOC\\_CLASS\\_CODE=PL&FOLDER1\\_REF=575133](http://planpub.eppingforestdc.gov.uk/NIM.websearch/ExternalEntryPoint.aspx?SEARCH_TYPE=1&DOC_CLASS_CODE=PL&FOLDER1_REF=575133)

**CONDITIONS**

- 1 The development hereby permitted must be begun not later than the expiration of three years beginning with the date of this notice.
- 2 There should be no obstruction above 600mm in height within a 2m wide parallel band visibility splay as measured from and along the nearside edge of the carriageway across the entire site frontage. Such vehicular visibility splays shall be provided before the access is first used by vehicular traffic and retained as such in perpetuity.
- 3 Prior to first use of the vehicular access it shall be constructed at right angles to the highway boundary and to the existing carriageway. The width of the access at its junction with the highway shall not be less than 3 metres and shall be provided with an appropriate dropped kerb vehicular crossing of the footway.
- 4 There shall be no discharge of surface water onto the Highway.
- 5 Any gates provided at the vehicular access shall be inward opening only and shall be set back a minimum of 6 metres from the back edge of the carriageway.